

BucketDescaler™ QUICK START Instructions


1. Connect an outlet hose to an access valve



2. Connect the return hose to an access valve



3. Fill Bucket with 1&1/2 gallons of water



4. Pour in ½ gallon of SpeedyBright™ descaling solution



5. Circulate for 20 minutes.

ACCESSORIES

SpeedyBright™

Classified by UL to NSF/ANSI Standard 60 biodegradable chemical for descaling drinking water systems. SpeedyBright will quickly dissolve calcium carbonate and other water-based scale deposits.

- SpeedyBright to water, respectively.
 - 1:3, for light cleaning.
 - 1:2, for medium cleaning.
 - 1:0 (full strength), for heavy cleaning.



SC-DS-HS-OTLT

Six foot high grade replacement hose for in/out water and bucket



SC-DS-EXTHOSE

Set of two six foot high grade hoses for those hard-to reach applications



SC-DS-5-VLV-KIT

Allows the operator to use a second tank or siphon additional chemical on larger applications.



SC-DS-PH-PAPER

pH testing paper, 12 ft.
Used to test for acidity.

